

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Gridspertise S.r.l.
Via Ombrone, 2
Rome – 00198
Italy

Measuring instrument A static **Active Electrical Energy Meter**
Type : Globy-T

Manufacturer's mark or name : Gridspertise S.r.L.

Reference voltage : 3x230/400 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network

Accuracy class : A or B

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12880 revision 0;
- Documentation folder T12880-1.

Valid until 9 September 2034

Initially issued 9 September 2024

Issuing Authority

NMI Certin B.V., Notified Body number 0122
9 September 2024

Certification Board