

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 17 of Directive 2014/32/EU, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer Gridspertise S.r.l.
Via Ombrone, 2
Rome – 00198
Italy

Measuring instrument A static **Active Electrical Energy Meter**

Type	: Globy-M
Manufacturer's mark or name	: Gridspertise S.r.l.
Reference voltage	: 240 V or 230 V
Reference current	: 5 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: B
Environment classes	: M2 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12881 revision 0;
- Documentation folder T12881-1.

Valid until 9 September 2034

Initially issued 9 September 2024

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
9 September 2024

Certification Board