

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Gridspertise Srl  
Via Ombrone 2  
00198 Roma,  
Italia

Measuring instrument A static **Active Electrical Energy Meter**

Type : Globy-M  
Manufacturer's mark or name : Gridspertise Srl  
Reference voltage : 120 V or 220 V or 230 V or 240 V  
Reference current : 5 A  
Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network  
Accuracy class : A or B  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
- Description T12908 revision 0;  
- Documentation folder T12908-1.

Valid until 31 October 2034

Initially issued 31 October 2024

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
31 October 2024

Certification Board