

# EU-type examination certificate

Number **T12909** revision 4  
Project number 3857969  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Gridspertise Srl  
Via Ombrone 2  
00198 Roma  
Italia

Measuring instrument **A static Active Electrical Energy Meter**

Type : Gridspertise  
Manufacturer's mark or name : Globy-T, Globy-S  
Reference voltage : Globy-T: 3x230/400 V...3x240/415 V  
Globy-S: 3x120/208 V...3x230/400 V;  
3x240/415 V  
Reference current : Globy-T: 5 A  
Globy-S: 1 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
Accuracy class : Globy-T: A or B  
Globy-S: A or B  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C  
Further properties are described in the annexes:  
- Description T12909 revision 4;  
- Documentation folder T12909-4.

Valid until

14 February 2035

Initially issued

14 February 2025

Remark

This revision replaces the earlier versions, including its documentation folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
8 July 2025

Certification Board