



# EU-type examination certificate

Number **T12909** revision 5  
Project number 3979537  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Gridspertise Srl  
Via Ombrone 2  
00198 Roma  
Italia

Measuring instrument **A static Active Electrical Energy Meter**

Type : Gridspertise  
Manufacturer's mark or name : Globy-T, Globy-S  
Reference voltage : Globy-T: 3x230/400 V...3x240/415 V  
Globy-S: 3x120/208 V...3x230/400 V;  
3x240/415 V  
Reference current : Globy-T: 5 A  
Globy-S: 1 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
Accuracy class : Globy-T: A or B  
Globy-S: A or B  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C  
Further properties are described in the annexes:  
- Description T12909 revision 5;  
- Documentation folder T12909-4.

Valid until

14 February 2035

Initially issued

14 February 2025

Remark

This revision replaces the earlier versions, except for its documentation  
folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
31 July 2025

Certification Board

**NMi Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that  
no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at [http://](http://ec.europa.eu/growth/tools-databases/nando/)  
[ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.

