

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Shanghai Fengyilong Electronic Co., Ltd.
No.5 Hangdu Road, Hangtouw
201316 Pudong
China

Measuring instrument A static **Active Electrical Energy Meter**

Type : DRS-205A V, DRS-205C V, DRS-205D V,
DRS-205C CT V

Manufacturer's mark or name : Forlong

Reference voltage : 230 V

Reference current : 5 A (Direct Connected variants)
1,5 A (Current Transformer operated variant)

Destined for the measurement of : electrical energy, in a
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -25 °C / +55 °C
-40 °C / +70 °C (DRS-205C CT V)

Further properties are described in the annexes:

- Description T12918 revision 0;
- Documentation folder T12918-1.

Valid until 13 March 2035

Initially issued 13 March 2025

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
13 March 2025

Certification Board