

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Shanghai Fengyilong Electronic Co., Ltd.
No.5 Hangdu Road, Hangtouw
201316 Pudong
China

Measuring instrument A static **Active Electrical Energy Meter**

Type : DRT-341A V, DRT-341D (CT) V,
DRT-341C (CT) V

Manufacturer's mark or name : Forlong

Reference voltage : 3x230/400 V

Reference current : 5 or 10 A (DRT-341A V, DRT-341D V)
10 A (DRT-341C V)
1,5 A (DRT-341C CT V, DRT-341D CT V)

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T12919 revision 0;
- Documentation folder T12919-1.

Valid until 13 March 2035

Initially issued 13 March 2025

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
13 March 2025

Certification Board