

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer AST (Advanced Sensor Technologies) International GmbH
Bärental 26
75365 Calw
Germany

Measuring instrument A **static DC electrical energy meter** intended to be integrated in a EV charging system

Type : DC Meter 1500
Manufacturer's mark or name : AST (Advanced Sensor Technologies) International GmbH
Reference voltage : 150 VDC ... 1.000 VDC
Reference current : 300 A
Destined for the measurement of : electrical energy, in a
- DC electrical network
Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes
– Description T12952 revision 0
– Documentation folder T12952-1

Valid until 18 June 2035
Initially issued 18 June 2025

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
18 June 2025

Certification Board