

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer **ALGODUE ELETTRONICA SRL**
Via P. Gobetti 16/F
28014 – Maggiore (NO)
Italy

Measuring instrument **A static Active Electrical Energy Meter**

Type	: UEM100-A R, UEM100-A M
Manufacturer's mark or name	: ALGODUE ELETTRONICA SRL
Reference voltage	: 3x230/400 V; 3x400 V; 230 V
Reference current	: 10 A
Destined for the measurement of	: electrical energy, in a - three-phase four-wire network - three-phase three-wire network - single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12965 revision 0;
- Documentation folder T12965-1.

Valid until 21 February 2035

Initially issued 21 February 2025

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
21 February 2025

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.