

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer ABB LV Installation Materials Co., Ltd. Beijing
No. 17 Kangding Street
Beijing Economic-Technological Development Area 100176
China

Measuring instrument A **static DC energy meter** intended to be integrated in an EV charging system

Type : DID 15-ME 650 Modbus and
DID 15-ME 200 Modbus

Manufacturer's mark or name : ABB LV Installation Materials Co., Ltd.
Beijing

Reference voltage : 150 VDC ... 1000 VDC

Reference current : 130 A (DID 15-ME 650 Modbus)
40 A (DID 15-ME 200 Modbus)

Destined for the measurement of : electrical energy, in a
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
– Description T12976 revision 1;
– Documentation folder T12976-2.

Valid until 28 February 2035

Initially issued 28 February 2025

Remarks This revision replaces the earlier version(s), including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
27 May 2025

Certification Board