

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Lumel S.A  
ul. Słubicka 4  
65-127 Zielona Góra  
Poland

Measuring instrument A static **Active Electrical Energy Meter**

Type : NMID30-2 V1  
Manufacturer's mark or name : Lumel S.A.  
Reference voltage : 3x230/400 V; 3x400 V; 230 V  
Reference current : 10 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- three-phase three-wire network  
- single-phase two-wire network  
Accuracy class : B or C  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C  
Further properties are described in the annexes:  
- Description T12996 revision 0;  
- Documentation folder T12996-1.

Valid until 17 March 2035

Initially issued 17 March 2025

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
17 March 2025

Certification Board