

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Controlin BV
Glasblazerstraat 1
2984 BL Ridderkerk
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : SKD-100-M V1
Manufacturer's mark or name : Controlin
Reference voltage : 230 V
Reference current : 10 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : B or C
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T13011 revision 0;
- Documentation folder T13011-1.

Valid until 23 May 2035

Initially issued 23 May 2025

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
23 May 2025

Certification Board