

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Bennett + Sauser AG, Tanksysteme Industriestrasse 6 CH-4528 Zuchwil Switzerland
Measuring instrument	<b>A Fuel Dispenser</b> Type : BSx/x-x-x, EM8xx-x-x, BSxx-x-x Accuracy class : 0,5 Environment classes : M2 / E1 Temperature range liquid : -5 °C / +35 °C Temperature range ambient : -25 °C / +55 °C  See for the flow ranges $Q_{\min}$ - $Q_{\max}$ chapter 1.2 of the description See for the liquid viscosity ranges $Q_{\min}$ - $Q_{\max}$ chapter 1.2 of the description  Further properties are described in the annexes: - Description T10188 revision 2; - Documentation folder T10188-2.
Valid until	8 April 2019
Remarks	This revision replaces the earlier versions, including its documentation folder.  The fuel dispenser may be combined with one or more LPG- and/or gasoline oil dispensers and/or measuring installations for AdBlue, which make use of the same or separate calculating/indicating device(s).

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
19 September 2013



C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
applicant shall indemnify third-party liability.  
  
The designation of NMi Certin BV.as Notified  
Body can be verified at [http://  
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge  
objection against this decision,  
within six weeks after the date of  
submission, to the general manager  
of NMi (see [www.nmi.nl](http://www.nmi.nl)).  
  
Reproduction of the complete  
document only is permitted.